

Engineering has reviewed the plans for the Dungannon Village project submitted March 31, 2016 and have the following comments:

1. SWMP Application; II. Permit Information; No. 1: Please revise this section accordingly as Dungannon drains to an offsite system. Add the State permit number.
2. SWMP Application; II. Permit Information; No. 2: Please revise this section accordingly as Dungannon required an offsite permit. Add the State permit number.
3. SWMP Application; IV. Project Information; No. 14: Please complete this section for just the portion of the site being collected by the onsite stormdrain system. The numbers will match the drainage area map (C1.1). Don't include the drainage area and associated impervious being collected in Dungannon Boulevard.

You need only submit the pages needing revisions via email to me at Richard.Christensen@wilmingtonnc.gov. Engineering will have no further comments upon receipt of the revised application. Please call or email if there are any questions. Thank you.